

**CITY of
SPRINGFIELD**



July 23, 1993

Mr. Tom Hembree
Aesthetic Concerns, Ltd.
326 Boonville Av.
Springfield, MO 65806

Dear Mr. Hembree:

On Friday, July 2, 1993, this office received a complaint from the Health Department about furniture stripping waste running off your property onto an adjacent lot. We investigated this complaint and found that the drain on your lot which takes rinsewater from the parts being stripped was stopped up. A plumber had been called to fix the drain.

While doing an inspection of the rinse area, we noticed that the drain was not covered. Chapter 30, "Wastewater Regulations," of the Springfield City Code states in section 30-23 that, "A person shall not contribute substances to the POTW which may":

(18) Contain storm water, surface water, ground water, well water, roof runoff, sub-surface drainage, swimming pool drainage, condensate, deionized water, cooling water, and unpolluted wastewater, unless specifically authorized by the Director.

Therefore, we are requiring you to cover the area over the outside drain in order to keep storm water and storm water runoff out of the City's sanitary sewer.

The rinsewater from the stripping operation is acceptable in the City's sanitary sewer as long as it meets the discharge requirements stated in Chapter 30, specifically sections 30-23 and 30-24(a).

Enclosed is a copy of Chapter 30 of the Springfield City Code. We are also requesting a copy of the Material Safety Data Sheets for any compounds, such as the furniture stripping chemicals, which are discharged to the sanitary sewer for our files.

326 BOONVILLE AV.

Mr. Tom Hembree
Aesthetic Concerns, Ltd.
Page 2
July 23, 1993

If you have any questions, please don't hesitate to call
864-1923.

Yours truly,

A handwritten signature in cursive script, reading "Karen Chandler".

Karen Chandler
Water Pollution Control Inspector
Surveillance & Enforcement

cc: Mr. Robert R. Schaefer, Superintendent of Sanitary
Services
Mr. J. R. Lyman, Sewer Surveillance & Billing Super-
visor
Mr. Tom Fare, Public Health Investigator
Mr. G. Borgstadt, Director of Building Regulations

TELEPHONE LOG SHEET

INDUSTRY NAME

Aesthetic Concerns

CONTACT PERSON

Tom Hembree, owner

NUMBER CALLED

DATE

7/28/93

TIME

1:50 pm.

PURPOSE FOR CALL

Tom Hembree of Aesthetic Concerns called about my letter. He said on Thursday & Friday of this week their plumber was going to put in a sump pit on that outside drain to keep the paint sludge out of it. He also said they were going to cover it and fence it on two sides. He said they would put a curb on it to keep out storm water. He said they only use sodium hydroxide in their process and he would send an MSDS sheet. I asked what he did with the paint solids he collected. He said he put them in a 55 gallon barrel (he fills about one a year) and a waste

(OVER)

CALLERS SIGNATURE

Karen Chandler

MEMORY TRANSMISSION REPORT

TIME : 11-22-'04 15:02
FAX NO.1 : 417-864-1918
NAME : COS Sewer Maint

FILE NO. : 331
DATE : 11.22 15:00
TO : 98239659
DOCUMENT PAGES : 5
START TIME : 11.22 15:01
END TIME : 11.22 15:02
PAGES SENT : 5
STATUS : OK

*** SUCCESSFUL TX NOTICE ***

Public Works Department

Surveillance Enforcement and Billing
Sewer Maintenance
1216 W. Nichols
Springfield, MO 65802
Phone: 417/864-1923
Fax: 417/864-1918



Date: 11-22-04 Fax #: 823-9459
To: Liz Ardel - Environmental Works
From: Gene Pabst
Message: Information on 326 N. Boonville
Pages to follow: _____

326 N. Boonville